



**A**  
**CWF Flooring, Inc.**  
**Company**



**CERTIFICATE OF COMPLIANCE**  
**ASTM D178-01**  
**TYPE II, CLASS 2 DIAMOND**

www.SwitchBoardMat.Com

TEST	SPECIFICATIONS	RESULTS
ELECTRICAL PROOF TEST ASTM D178	MIN. 20,000V FOR 1 MINUTE	PASS
DIELECTRIC BREAKDOWN TEST ASTM D149	MIN. 30,000V	PASS
O <sub>3</sub> RESISTANCE TEST METHOD B ASTM D 178	ANY VISUAL DEGRADATION	PASS
TENSILE STRENGTH ASTM D412 DIE C	MIN. 700PSI	1318 PSI
ELONGATION ASTM D412 DIE C	MIN. 250%	317%
TENSION SET ASTM 412 DIE B	MAX. 0.50 IN.	0.4827 IN.
MOISTURE ABSORPTION ASTM D570	MAX. INCREASE 3%	0.09%
ACCELERATED AGING ASTM D573	MIN. 50% OF ORIGINAL TENSILE STRENGTH	1363 PSI (103%)
FLAME RESISTANCE ASTM D178 APPENDIX	MAX. 0.5 IN./12.7 MM AFTER 30S	0.12 MM/S
OIL RESISTANCE ASTM D471	MAX. VOLUME INCREASE 4%	-0.04%

I certify that these are the nominal results for Production Testing of the ASTM D178-01 specification as outlined above.

Written by:   
QUALITY ASSURANCE SUPPORT TECHNICIAN

Print Name: Christopher Hurst

Date: 06/14/2016

LOT # 154865